

120VAC line voltage supply to AGS Merlin Panel 12-14AWG 3/4" COND.



120VAC from AGS Merlin Panel 12-14AWG 3/4" COND.

Normally Closed 18-22 AWG Dry Contact

+ & - 24VDC Normally Closed 18-22 AWG Dry Contact

Normally Closed 18-22 AWG Dry Contact

AGS GAS DETECTOR TFT



- HOT
- NEUTRAL
- GROUND
- LOW VOLTAGE



Client	
Job Title	
Drawing Title	

Notes
 All discrepancies between information shown on the drawing and information in the specification to be referred to American Gas Safety prior to proceeding.

Copyright in all documents and drawings prepared by American Gas Safety and any work executed from these documents shall, unless otherwise agreed, remain the property of American Gas Safety.

Amendments		
Scale	Date	Drawn
N.T.S.		BT
Dwg. No. 1500S & CO TFT		Rev. 1