

Merlin RG Series



This document provides details on Modbus functionality of the Merlin RS range.

Every effort is made to ensure the accuracy of this document; however, AGS can assume no responsibility for any errors or omissions in this document or their consequences. AGS would greatly appreciate being informed of any errors or omissions that may be found in the content of this document. For information not covered in this document, or if there is a requirement to send comments/corrections, please contact AGS using the contact details given below.

RG = Refrigerant Gas NOTE: temperature and humidity functions are disabled

Parity: None / Data-Word length: 8-bit / Stop bit: 1

Register/Address	Description	Notes	Read/Write
40000-40019	Reserved		
40020	Baud Rate	Type: uINT, Factor:1 9600 (Default), 19200, 38400, 57600 via dipswitch	R
40021	Address	Type: uINT, Factor:1, 0-127 via DIP Switch	R
40022	Name	ASCII character	R
40023	Name	ASCII character	R
40024	N/A	N/A	R
40025	RG	Type: INT, Factor: 1, Unit: ppm	R
40026	Temperature	Type: INT, Factor: 10, Unit: °C/F	R
40027	Humidity	Type: INT, Factor: 10, Unit: %RH	R
*40028	RG +10V O/P	Type: INT, Factor: 10, Unit: V	R / R/W
*40029	Temperature +10V O/P	Type: INT, Factor: 10, Unit: V	R / R/W
*40030	Humidity +10V O/P	Type: INT, Factor: 10, Unit: V	R / R/W
40031	RG Offset	Type: INT, Factor: 1, Unit: ppm (-5000 to 5000)	R/W
40032	Temperature Offset	Type: INT, Factor: 10, Unit: °C/F (-100/4 to 100/140)	R/W
40033	Humidity Offset	Type: INT, Factor: 10, Unit: %RH (-100 to 100)	R/W
40034	Pre-Alarm Level (Low)	Type: INT, Factor: 1, Unit: ppm (0 to 5000ppm) Default 175ppm	R/W
40035	Alarm Level (High)	Type: INT, Factor: 1, Unit: ppm (0 to 5000ppm) Default 1000ppm	R/W
40036	Relay Set Point	Type: INT, Factor: 1, Unit: ppm (0 to 5000ppm) Default 1000ppm	R/W
40037	Relay Alarm	Type: INT, Factor: 1, 0: (No alarm) 1: (Alarm, relay changed status)	R
40038	Relay Polarity	Type: INT, Factor: 1, 0: Normal (N/O) 1: Reversed (N/C)	R/W
40039	Temperature Unit	Type: INT, Factor: 1, 1: °C 2: °F	R/W

40040	RG Alarm Status	Type: INT, Factor: 1, 1: (No alarm) 2: (Pre-Alarm) 3: (Alarm)	R
40041	RG Maximum	Type: uINT, Factor: 10, Unit: ppm (0 to 5000ppm)	R/W
40042	RG Minimum	Type: uINT, Factor: 1, Unit: ppm (0 to 5000ppm)	R/W
40043	RG Voltage Max	Type: uINT, Factor: 10, Unit: V (0 to 10V)	R/W
40044	RG Voltage Min	Type: uINT, Factor: 10, Unit: V (0 to 10V)	R/W
40045	Temperature Max	Type: INT, Factor: 10, Unit: °C/°F (-20 to 60°C)	R/W
40046	Temperature Min	Type: INT, Factor: 10, Unit: °C/°F (-20 to 60°C)	R/W
40047	Temp Voltage Max	Type: uINT, Factor: 10, Unit: V (0 to 10V)	R/W
40048	Temp Voltage Min	Type: uINT, Factor: 10, Unit: V (0 to 10V)	R/W
40049	Humidity Max	Type: uINT, Factor: 10, Unit: %RH (0 to 100%)	R/W
40050	Humidity Min	Type: uINT, Factor: 10, Unit: %RH (0 to 100%)	R/W
40051	Humidity Voltage Max	Type: uINT, Factor: 10, Unit: V (0 to 10V)	R/W
40052	Humidity Voltage Min	Type: uINT, Factor: 10, Unit: V (0 to 10V)	R/W
40053	RG Voltage Feedback	Type: uINT, Factor: 10, Unit: V	R
40054	Temp Voltage Feedback	Type: uINT, Factor: 10, Unit: V	R
40055	Humidity Voltage Feedback	Type: uINT, Factor: 10, Unit: V	R
40056	RG Voltage Alarm	Type: INT, Factor: 1, 0: (No alarm) 1: (Alarm) +/-10% out	R
40057	Temperature Voltage Alarm	Type: INT, Factor: 1, 0: (No alarm) 1: (Alarm) +/-10% out	R
40058	Humidity Voltage Alarm	Type: INT, Factor: 1, 0: (No alarm) 1: (Alarm) +/-10% out	R
40059	Reserved		
*40060	RG +10V O/P (40028)	Type: INT, Factor: 1, 0: (O/P based on Writeable Value - 40028) 1: (O/P based on RG Sensor - 40028)	R/W
*40061	Temperature +10V O/P (40029)	Type: INT, Factor: 1, 0: (O/P based on Writeable Value - 40029) 1: (O/P based on Temperature sensor - 40029)	R/W
*40062	Humidity +10V O/P (40030)	Type: INT, Factor: 1, 0: (O/P based on Writeable Value - 40030) 1: (O/P based on Humidity Sensor - 40030)	R/W
*40063	Audible Alarm	Type: INT, Factor: 1, 1: Disabled 2: Enabled	R/W
40064	Error Code	Type: INT, Factor: 1	R
40065	Warning Code	Type: INT, Factor: 1	R

For more information visit www.bacnet.org

American Gas Safety LLC

american~~g~~assafety.com

6304 Benjamin Road, Suite 502, Tampa FL 33634



AGS is the owner of this document and reserves all rights of modification without prior notice.